10½

UP TO LIBRARIAN'S OFFICE #2 LEVEL.

FUTURE CARRELLS

FUTURE SWITCHES

FUTURE STACK ROOM

OPEN SHAFT FOR FUTURE STACKS

SPARE ROOM (FUTURE STACKS)

UP TO REFERENCE ROOM CLOCK

UP TO TOP FLOOR TEL.

SWITCH A'd ABOVE FUTURE #2 FLOOR

ELEVATOR

BOOK LIFT

FEEDERS TO #2 FLOOR PANEL NO. 1

L.P. "D" 18 CIR.

L.P. "C" 20 CIR.

L.P. "S" 8 CIR.

WRAPPING ROOM

PERIODICAL LIBRARIAN

RECEIVING ROOM

MENDING ROOM

UP TO MAIN FLOOR CLOCK

TO RESERVE ROOM CLOCK

TO STAIR IN FAN ROOM MAG.

TO CLOCK RELAY IN FAN ROOM

FIRE ALARM IN FAN ROOM

STAT. CONTROL TO 4TH FLOOR

DOWN TO 1ST FLOOR

UP TO 3RD FLOOR

UP TO LIBRARY

RAMP DOWN

UP TO OFFICES #3 LEVEL.

1" CO. TO MAIN TELEPHONE TERMINAL IN FAN ROOM.

FEEDER CONDUITS ABOVE EXISTING DUCT

¾" - 4 WIRE - EXHAUST FAN CONTROL TO PENT HOUSE

PULL BOX ON TOP OF DUCT. COVER ON TOP.

JANITOR'S ROOM

JANITOR'S STORAGE

FAN ROOM

WOMENS' LOCKER ROOM

EXIST. OUTLET AS JUNC. BOX.

EXISTING ASST. AS JUNC. BOX.

¾" CO. UP TO OFFICES #3 LEVEL TELEPHONE.

EXIT LIGHT

STOP-START & PILOT EXHAUST FAN CONTROL

MAIN SWITCHBOARD

NEW CORRIDOR

FUTURE LOCKER ROOM

NEW SWITCHES

EXISTING LIGHTS

NOTE-
ALL CONDUITS NOT OTHERWISE MARKED ARE ¾" CONDUIT ONLY. STROKES INDICATE NUMBER OF WIRES. USE #12 WIRE IN SPARE ROOM, RECEIVING AREA AND EXISTING BUILDING. USE #14 WIRE FOR BALANCE.

ELECTRICAL PLAN BASEMENT FLOOR STACK LEVEL NO. 2

REVISION DATE	ADDITION TO LIBRARY	SCALE
28 APRIL/47	UNIVERSITY OF B. C.	1/8" = 1'-0"
		DATE 25 JULY, 1946
	A. EDWARD SIMPSON ELECTRICAL ENGINEER VANCOUVER, B. C. / SHARP & THOMPSON ARCHITECTS VANCOUVER, B. C.	DRAWING NO. U2-5-2