SEE DWG No 6 FOR TYPICAL ELEV. OF STACK WINDOWS.

STACK AREA

MAIN TO RUN AT CEILING OF NO. THREE STACK LEVEL

EXISTING 6" SUPPLY MAIN TO THIS POINT

RESERVE ROOM

CATALOGUING DEPT.

OFFICE

PASSAGE

RED CROSS RM.

JANITOR

NOTE: 3 DUCTS JOINED TO ONE 16"x8" DUCT AT No 4 STACK CEILING 3 DUCTS ARE 1" APART.

SEE ISOMETRIC DETAIL "S"

BBG-H.&C. No 840 12"x6"-150 CFM

BBG-H.&C. No 840 12"x6"-150 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

BBG-H.&C. No 840 12"x6"-150 CFM

BBG-H.&C. No 840 12"x6"-150 CFM

ANEMOSTAT TYPE C SIZE 28 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 25 490 CFM

ANEMOSTAT TYPE C SIZE 45 1590 CFM

BBG-H.&C. No 840-10"x5"-100 CFM

BBG-H.&C. No 840-10"x5"-100 CFM

BBG-H.&C. No 840-10"x5"-100 CFM

BBG-H.&C. No 840-10"x5"-100 CFM

BBG-H.&C. No 840-100 CFM-10"x6"

BBG-H.&C. No 840-100 CFM-10"x6"

ANEMOSTAT TYPE C SIZE 15 175 CFM

3C-H-26"-85-18⅝ #

3C-H-26"-125-28 #

4C-H-32"-65-21 #

WG-H.&C. No 840 8"x4"-100 CFM

WG-H.&C. No 840 8"x4"-100 CFM

WG-H.&C. No 840 8"x4"-60 CFM

ISOMETRIC DETAIL "D"

NOTE: REVERSE LOCATION OF INTAKE GRILLES TO SUIT LOCATION OF ROOMS

SEE ISOMETRIC DETAIL "S"

SECTION OF No 2 STACK LEVEL SHOWING LAVATORY EXHAUST DUCTS.

REVISIONS

MK	DESCRIPTION	DATE

STACK LEVEL No 4

ADDITION TO LIBRARY

SCALE – 1/8" = 1'-0"

DATE – MAY 15, 1946

D.W. THOMSON - B.A.Sc, M.S. - HEATING & VENTILATION

SHARP & THOMPSON ARCHITECTS

DRAWING NUMBER 2

SET NUMBER U1B

UNIVERSITY OF B.C.